

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No.F.6/DFS/MS/School/2023/NDZ/339

Dated: 19/05/2023

FIRE SAFETY CERTIFICATE

Certified that the **Bhagirathi Bal Shiksha Sadan Sec School** located at **D-7/53, D Block, Gali No-7, Dayalpur Extn., Delhi 110094**, building comprised of **Ground plus Two upper Floors**, owned/occupied by **Bhagirathi Bal Shiksha Sadan Sec School**, was issued Fire Safety Certificate vide letter No. **F6/DFS/MS/School/2019/NDZ/1908** Dt. **03/10/2019**. The School building was re-inspected by the officer concerned of this department on **11/05/2023** in presence of **Sh. Naresh Sharma** and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with the Fire Prevention and Fire Safety requirements in accordance with Circular No. **262-362** dated **17/01/2005** issued by Director of Education and that the building is fit for occupancy class "Educational" (Group-B) and valid up to **31/03/2026** (three years) in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rule 2010

Issued on 19/05/2023 at New Delhi by.


(ATUL GARG)
DIRECTOR

DELHI FIRE SERVICE

Copy to:-

1. The Principal, Bhagirathi Bal Shiksha Sadan Sec School located at D-7/53, D Block, Gali No-7, Dayalpur Extn., Delhi 110094.
2. Director of Education, B-Block, Yamuna Vihar, North East, Delhi-110053

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided therein shall be maintained in good working conditions at all times.
2. Loss of life or property due to non-functional fire safety measure shall be at the responsibility of the Management
3. The trained fire fighting staff should be available round the clock
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency
5. This certificate cannot be treated in any case for regularizations of unauthorized construction, if any
6. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry"
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in