

C 24

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F.6/DFS/MS/School/2026/EZ/126

Dated: 07/08/2026

FIRE SAFETY CERTIFICATE

Certified that the Bhagirathi Bal Shiksha Sadan Sec. School at D-7/53, D-Block, Gali No 7, Dayalpur Extn., Delhi-110094, comprised of ground plus two upper floors, owned/occupied by Bhagirathi Bal Shiksha Sadan Sec. School, was issued Fire Safety Certificate by this department vide letter No. F.6/DFS/MS/School/2023/NDZ/339 dated 19/05/2023. The premise was re-inspected by the officer concerned of this department on 20/07/2026 in the presence of Sh. Naresh Sharma (Manager) and found that the said building/premises have complied with the fire prevention and fire safety requirements in accordance with DOE Circular No. 262-362 dated 17/01/2005 and that the building is fit for occupancy class "Educational Group-B" with effect from 07/08/2026 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the DFS Rules, 2010.

Issued on 07/08/2026 at New Delhi by



Manager
Bhagirathi Bal Shiksha Sadan Sec. School
Recognised & Affiliated to C.B.S.E.
D-Block, Gali No. 7 Dayalpur Extn
Delhi-110094



Principal
Bhagirathi Bal Shiksha Sadan Sec. School
Recognised & Affiliated to C.B.S.E.
D-Block, Gali No. 7 Dayalpur Extn
Delhi-110094



(Dr. S.K. Tomar)
Chief Fire Officer
Delhi Fire Service



Copy to: -

1. The Deputy Director of Education, Govt. of National Capital Territory of Delhi, B-Block, Yamuna Vihar, Delhi-110053
2. The Principal, Bhagirathi Bal Shiksha Sadan Sec. School at D-7/53, D-Block, Gali No 7, Dayalpur Extn., Delhi-110094

Conditions for the validity of Fire Safety Certificate:

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working conditions at all time as seen during inspection.
3. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
4. All the staff members must know the correct method of operation of fire-fighting system.
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, prior to its expiry.
7. The owner/occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in