



No.DJB/QCLTYR/PD/260406

DELHI JAL BOARD
(GOVT. OF N.C.T. DELHI)
QUALITY CONTROL LABORATORY,
TRANS YAMUNA REGION TAHIRPUR DELHI-110093



Licence No- CRO/QM/L-8004274-1 as per IS/ISO 9001:2015



NO: DJB/ACWA(TYR)/2026.....

DATE:- 30-04-2026

Analysis report of water samples collected from (1) Inlet (Bore water), (2) Outlet (After R.O.) of BHAGIRATHI BAL SHIKSHA SADAN, D-7/53, D- BLOCK, GALI NO. 7, DAYALPUR EXTENSION, DELHI-110094 for drinking purpose.

Ref. No. BBSSS/MANAGER/101,
Challan No: - 30,

dated: - 17.04.2026
dated: - 24.04.2026

ACWA-TYR

Diary No. 104 dt. 07.05.2026

Date of collection: 28.04.2026

S. No.	PARTICULARS	BIS:10500-2012 LIMITS		UNITS	RESULT	
		Desirable	Permissible		(1)	(2)
A.	Physical Examination					
1.	Colour	...	...	-	CLEAR	CLEAR
2.	Odour	...	...	-	UNOBJ.	UNOBJ.
3.	Turbidity	1.0	5.0	NTU	0.86	0.75
4.	pH Value	6.5-8.5	--	-	7.4	6.8
5.	Electrical Conductivity	--	--	µs/cm	1388	198
6.	Total Dissolved Solids	500	2000	mg/l	902	129
B.	Chemical Examination					
7.	P th Alkalinity	...	...	mg/l	NIL	NIL
8.	Total Alkalinity	200	600	mg/l	446	38
9.	Total Hardness	200	600	mg/l	422	32
10.	Calcium as (Ca)	75	200	mg/l	57.6	7.2
11.	Magnesium as (Mg)	30	100	mg/l	66.72	3.36
12.	Ammonical Nitrogen	0.5	NR	mg/l	N.D	N.D
13.	Nitrite			mg/l	N.D	N.D
14.	Nitrate	45	NR	mg/l	74.12	15.58
15.	Sulphate	200	400	mg/l	131.95	4.83
16.	Chloride	250	1000	mg/l	124	20
17.	Fluoride	1.0	1.5	mg/l	0.81	0.04
18.	Dissolved Iron	1.0	NR	mg/l	0.08	0.06
19.	Cyanide	0.05	NR	mg/l	N.D	N.D
20.	Residual Chlorine	0.2	1.0	mg/l	NIL	NIL
C.	Bacteriological Examination					
21.	Coliform count	Absent	NR	MPN/100ml	28	0

REMARKS:- (1) On the basis of above tested parameters, water sample (1) does not conform to the prescribed limits and cannot be considered fit for drinking purpose.

(2) On the basis of above tested parameters, water sample (2) conforms to the prescribed limits and can be considered fit for drinking purpose.

(B. Sheikh Lal)
ACWA(TYR)

(A.G. Susmitha)
BACTERIOLOGIST

(Gulesh Jainar)
CHEMIST

(Mayank Yadav)
A/CHEMIST

Principal

Bhagirathi Bal Shiksha Sadan Sec. School
Recognised & Affiliated to C.B.S.E
D-Block, Gali No. 7 Dayalpur Extn
Delhi-110094

Manager

Bhagirathi Bal Shiksha Sadan Sec. Schr
Recognised & Affiliated to C.B.S.E
D-Block, Gali No. 7 Dayalpur Extn
Delhi-110094

**MUNICIPAL CORPORATION OF DELHI
PUBLIC HEALTH DEPARTMENT
SHAHDARA NORTH ZONE**

No. DHO/Shah (N)/2026/ D - 343

Dated: 20/8/26

SCHOOL INSPECTION REPORT

In reference to your application duly submitted in the office of undersigned vide diary no. 663 dated 18.08.2026, the inspection of "BHAGIRATHI BAL SHIKSHA SADAN" at D-7/53, Dayalpur, Delhi-110094 was carried out on dated 19.08.2026. During the inspection, it was found that the school is running under satisfactory sanitary & hygienic conditions, provision of latrines & urinals is sufficient according to the number of students and has safe drinking water facilities for the students and members of staff of the institution.

In view of the above findings, undersigned is hereby pleased to grant "PROVISIONAL NO OBJECTION CERTIFICATE FROM HEALTH POINT OF VIEW" to the above-said school. This certificate is valid for a period of one year from the date of issue.



**Dy. Health Officer
Shahdara North Zone**
उप-स्वास्थ्य अधिकारी
शाहदरा उत्तरी क्षेत्र
दिल्ली नगर निगम

**Manager
BHAGIRATHI BAL SHIKSHA SADAN
D-7/53, Dayalpur
Delhi-110094**



Principal
Bhagirathi Bal Shiksha Sadan Sec. School
Recognised & Affiliated to C.B.S.E
D-Block, Gali No. 7, Dayalpur Extn
Delhi-110094



Manager
Bhagirathi Bal Shiksha Sadan Sec. Schr
Recognised & Affiliated to C.B.S.E
D-Block, Gali No. 7, Dayalpur Extn
Delhi-110094